



## Bruto Akoestische Isolatie - Geluidscabine

Oprichtgever

Meyer Noise Control

Meetplaats

Academie Muziek-Woord-Dans - Heist-op-den-Berg

Omstandigheden

Lokaal 1.8 - Isolatiemeting van binnen naar buiten

Meetdatum

22/mrt/16

**KU LEUVEN**

f (Hz)	$D_{nT}$ 1/3 oct. (dB)	$D_{nT}$ 1/1 oct. (dB)
--------	---------------------------------	---------------------------------

50	25.4	
63	30.3	26.15
80	24.6	
100	28.1	
125	30.5	30.4
160	35.2	
200	37.8	
250	38.9	39.6
315	44.9	
400	46.2	
500	47.8	48.1
630	52.3	
800	49.4	
1000	51.3	50.9
1250	52.7	
1600	54.3	
2000	58.3	56.6
2500	58.8	
3150	61.2	
4000	62.3	62.4
5000	64.1	

Bruto Akoestische Isolatie - dB

